



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	12-05-02	Interpretation #	02-056
Topic	R-2 Occupancies		
Code Section(s)	Section 506 (#6), California Building Code (1998 ed)		
Requested by	Pedro Garcia/Steve Kuchenski 310 North Lake Avenue #920 Pasadena, CA 91101-4129		

Does Provision #6 in Section 506 refer to Section 904.2.9 or does it refer to Group R, Division 2 occupancies referenced in Section 904.2.10?

Provision #6 refers to Group R, Division 2 occupancies. Provision #6 is a misprint and should refer to Section 904.2.10 as this section is where the sprinkler requirements for Group R, Division 2 occupancies reside.